

**Before Storing Biodiesel
Complete the Attached Steps
to Meet the Interim Regulations
For Compatibility and Leak Detection !**

When Can an Owner/Operator Deliver and Store Biodiesel Blends
Greater than B5, up to Including B20?

	<u>UST and Component <i>Compatibility</i>:</u> Double Wall UST & Components	
Step 1	UST listed/approved for use with petroleum diesel?	If UST is not approved for use by an independent testing organization for petroleum diesel then this variance is not applicable, do not proceed.
Step 2	Is the UST in Compliance?	If facility is not in compliance then do not proceed. Bring facility into operational compliance.
Step 3	Notice of Intent	If Step 1 and 2 are complete, then a Notice of Intent to store biodiesel must be submitted to the CUPA.
Step 4	Tank Form	Revised Tank Form must be submitted to CUPA.
Step 5	Compatibility Documentation	A written statement from the <u>owner</u> that the UST and components are compatible with the biodiesel blend stored. Statement shall be supported by documentation from the UST manufacturer, a nationally-recognized biodiesel association, or a nationally-recognized research organization.
Step 6	Owners/operators shall consult with the CUPA after submittal of all required documentation for direction to proceed.	

When Can an Owner/Operator Deliver & Store
Biodiesel Blends up to B20?

	<u>Leak Detection <i>Functionality</i>:</u> Double Wall UST & Components	
Step 1	Is the UST in Compliance?	If facility is not in compliance then do not proceed. Bring facility into operational compliance.
Step 2	Notice of Intent	If facility is in compliance then Notice of Intent to store biodiesel must be submitted to the CUPA.
Step 3	Tank Form	Revised Tank Form must be submitted to CUPA.
Step 4	Leak Detection Functionality Documentation	A written statement by the <u>owner</u> that the leak detection method or equipment functions with the biodiesel blend stored. This statement shall be supported by documentation from the manufacturer of the release detection method or equipment.
Step 5	Owners/operators shall consult with the CUPA after submittal of all required documentation for direction to proceed.	